



PATENT No. 729909

DO NOT SCALE

DIMENSIONS MAY VARY BY PLUS OR MINUS 2.5% DUE TO THE ROTATIONAL MOULDING PROCESS



\*THESE DIMENSIONS ARE THE MAXIMUM DEPTH OF TANKS ON A FLAT SITE.

\*TANK LAYOUT IS INDICATIVE ONLY AND CAN BE ALTERED TO SUIT SITE CONDITIONS, INCLUDING ABOVE GROUND INSTALLATION.

\*FOR DETAILS OF LIFTING AND ANCHOR POINTS REFER TO STD. DRAWING GTL-0000-10.

\*ANCHOR POINTS EQUISPACED AROUND TANKS AND SHOULD BE MATCH MARKED ON SITE FOR INSTALLATION.

\*THE 200 MINIMUM UNDER BEARER CLEARANCE DIMENSION ALLOWS THE CORRECT ASSEMBLY OF THE PEDESTAL, DROPPER TUBE AND TANK. DESIGN OF FLOOR STRUCTURE NEEDS TO CONSIDER THESE DIMENSIONAL PARAMETERS.

\* DISCHARGE LOADING 87 LITRES PER DAY.

DO NOT BURY TANKS BELOW DIMENSIONS SHOWN

No.	DATE	BY	DESCRIPTION	APPROV.
A	11.12.03	S.N.	CLEARANCE ABOVE PRIMARY TANK INCREASED	ANDREW GOUGH
REVISION				APPROV.



Gough Industries Pty. Ltd.  
 833 Ingham Road  
 Bohle, Townsville  
 P.O. Box 1258, Aitkenvale, Qld. 4814  
 Telephone 07 47747606  
 Facsimile 07 47747608  
 A.C.N. 010 028 547

This drawing remains the property of Gough Industries Pty. Ltd. It is subject to Gough Industries Pty. Ltd.'s recall and must not be reproduced in part or whole or it's contents divulged to third parties without prior written approval from Gough Industries Pty Limited.

Signature	Date
DRAWN S.NAGY	24.02.03
DRN. CHK	
ENGINEER	
ENG. CHK	
Eng. APPROVAL	

25 PERSON HYBRID TOILET SYSTEM SINGLE PEDESTAL, MICROFLUSH, 2500LT HOLDING TANK GENERAL ARRANGEMENT DETAILS			
SCALE	1:60	A4	Gough Plastics Drg. No. HTS902.0001-13
CAD FILE:	H:\HYBRID TOILET SYSTEM\25 PERSON\SINGLE\		

REV

1

2

3

4

5

6