

1	Is the site level? Vehicles with holding tanks must have a roadway that is higher than the shroud.
2	Have you a copy of both optimal installation diagrams (levels and bi-directional)
3	Has the plumbing been installed to allow the shroud to be removed if necessary. (not glued)
4	Is there provision for a wash down tap as well as a potable water tap? Allow for a good separation between taps.
5	Has the plumber allowed for non return valves to prevent contamination (both taps)
6	Is there enough room for vehicles to manoeuvre
7	Can a driver download from the left as well as the right side of the vehicle?
8	Is there adequate signage to show non drinking water? The wash down hose IS NOT to be used for filling RV tanks or containers.
9	Is there suitable signage for directions to get to the dump point?
10	Is there a rubbish bin for rubbish and possibly a recycle bin as well.
11	Have all relevant stakeholders been consulted on the location (EG local council, user groups, caravan parks, water authority)
12	To prevent misuse, will the dump point need to be locked and a key be available locally ?