

Biomagic Dosage

ALL measurements below are to be added to a bucket of water eg 7 Litre

ALL mixes are to be made up and used fresh, not carried over to next use / next week.

Initial dose

- First add 200mls down each pedestal and then follow up with 100mls (weekly) down each pedestal for the first month.

Regular dose (weekly)

- 50mls down each pedestal.

Peak season dose (weekly)

- 200mls down each pedestal.

Low season dose (weekly)

- 20mls down each pedestal.

Suspected Porter Potty contamination

- 1 Litre down each pedestal, then follow up with 500mls (weekly) down each pedestal for the first month. This will work the majority of the time provided you act immediately, the longer you leave the system the harder it will be to recover. If you find the system has not recovered after this time period then it will need to be pumped out.

Cleaning

- Use Biomagic 1:1 in a spray pack. This can be used in and around the bowl area. Feel free to use disinfectants on the floor and walls, it is only the bowl and pedestal where disinfectants will be harmful and Biomagic must be used.

To assist in the breakdown of floating material within the primary tanks Biomagic can also be sprayed over the top via a spray pack. Use 1:1.

If you find you are getting a lot of odour coming through when the paper dampeners (wettors) are being used I recommend adding 100mls into each chamber of the secondary tank. This should only need to be done once as the primary tank liquid coming through will already have Biomagic mixed in with it.

NB. Biomagic must be mixed in with water (approx 7-10Litres) before being added to the system. If it is used on its own it will be a lot less effective. Mixing it with water increases the surface area that Biomagic comes in contact with and also adds weight so it can push deeper into the system.